


When integrating this assembly into the plant the common rules for electrical and mechanical safety as well as the submitted documentation must be observed. Dissemination, reproduction of this drawing as well as utilization of its contents and communication thereof to others without express authorization are prohibited. Offenders will be held liable for payment of damages.

All rights created by patent grant or registration of a utility model or design patent are reserved.



NOTE:

The layout will be adjusted according to the local conditions

The amount and the location of the lightning poles are indicative and will be adjusted to the local conditions in Allocated Design.

Note 1: Distance between building and transformers (and between each transformer) in accordance with Danish Regulations; Stærkstrømsbekendtgørelsen section 2, chapter 7.6.2.1 table 4

Note 2: Distance between HV live parts and fence in accordance with Danish Regulations; Stærkstrømsbekendtgørelsen section 2, chapter 6.7 figure 6.2.

Note 3: Distance between building and HV live parts in accordance with Danish Regulations; Stærkstrømsbekendtgørelsen section 2, chapter 6.7 figure 6.4.

REFERENCES:

Sections, see drawing no.: FD 025.857612

LEGEND:

- Possibility for access ramp
- Fence
- Trees and bushes
- Grass
- Transformers
- Gravel
- Concrete tiles
- Manhole cover
- Lightning pole
- Gratings

Revision	Description
00.04	Drawing name changed. Reference in note 1 changed to chapter 7.6.2.1. Approximation size of substation added
00.03	Lightning poles added
00.02	Note references on drawing added. North arrow deleted

	Verified	Address Banedanmark Amerika Plads 15 2100 København Ø		Consultant
	Replaces			
First edition Date and initials	Latest revision Date and initials	Scale 1:200	Drawing name Generic Design Type 1: AT Single transformer	
Drawn 14.04.2016 MOH	26.11.2016 MOH	Units		
Controlled 16.04.2016 ASL	28.11.2016 ASL	mm		
Approved 18.04.2016 KELI	30.11.2016 KELI			
© Copyright Banedanmark	Language English	Revision 00.04 30.11.2016	Drawing number FD 025.157614	Page/Pages 1/1